

DATE: March 31, 2016
SUBJECT: Letter of Clarification No. 2
RE: GRB Exterior Painting
TO: All Prospective Bidders

This Letter of Clarification is issued as part of the referenced solicitation for the purpose of amending the Section 3.0 of the Project Specifications, titled "Project Execution" in the following manner:

- 3.7 Thoroughly prepare all surfaces for painting as prescribed by the manufacturer.
 - 3.7.1 Remove all loose blistered, peeling, chalked crazed, map cracked or alligatored and otherwise defective paint down to sound work or bare surfaces.
 - 3.7.2 Clean all work areas with appropriate products to prepare for painting. Remove and cleanup all dust, dirt or sanded paint or other loose materials, then clean and dry.
 - 3.7.3 Perform a test of the epoxy prior to painting to test for potential "lifting" of the existing coating. This test is to be performed in a small area on one of the structures. Once the test has been completed, the removal of all loose and peeling existing paint will be performed, followed by handpressure washing to remove contaminants.
 - 3.7.4 HandPressure-wash all exterior areas and elements to be painted.

When issued, Letters of Clarification automatically become a part of the solicitation and supersede any previous specifications and/or provisions in conflict therewith. Bidders are responsible for ensuring that they have obtained any such previous letters associated with this solicitation. By submitting a bid, respondents shall be deemed to have received all Letters of Clarification and to have incorporated them into their respective bids.