

ADDENDUM 3 PreBid- DELTA 3

Project Name: The Houston Venue
Project Number: FRC 16001
Issued To: Bidders

Bid Set Issue Date: 04/26/2016
Addendum Date: 05/13/2016

A. NOTICE TO BIDDER

1. This addendum is issued pursuant to the Bidding Instructions as is hereby made part of the Bid Documents. This addendum serves to clarify, revise and supersede information found in the previously issued Bid Sets and Addenda. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Failure to do so may subject the Bidder to disqualification. A list of attachments, if any, is part of this document.

B. CLARIFICATIONS

1. On sheet E3.0 electrical schedules show dimming panels 'DMA and DMB to be 16 circuits each. On sheets E1.0A and E1.0B show locations where the fixture are tied into the dimming panels on circuits 17 and 18. Will the dimming panels need to be sized to accommodate these additional circuits? Response - Panel schedules DMA and DMB have been revised to comply. Refer to drawing E3.0 issued in addendum 2.

C. MODIFICATIONS TO PROJECT MANUAL

1. None

D. MODIFICATIONS TO DRAWINGS

1. None

E. ATTACHMENTS

1. None

