

[→ Click Here to View the Project](#)

If this link does not work, please go to <https://secure.smartbidnet.com/LBBU> and enter the access key: *****
Yes, I'll Bid All Codes | No, I Won't Bid this Job | [Click Here to View the Project](#)

This is a bid memo issued by the Houston Division:



From: Jim Ritsema
Phone: (713) 222-0900
Fax: (713) 222-1414
Fax:
Phone:
Trade Codes:

ATTN:
(or Estimating Department)

Company Name:

Address:

BID MEMO NO. 03 - A/V SCOPE CLARIFICATIONS

Title:

City Hall North Wing
Expansion

Location:

901 Bagby Street - Houston, TX 77002

Bid Due Date: July 21, 2015 02:00 PM (CT)

Architect:

Gensler

Owner:

Houston First Corporation / COH

Bid Project Status:

Open to Bid

Estimator: Jim Ritsema (jritsema@balfourbeattyus.com)

Bid Memo:

Please note the following questions and responses regarding the AV scope:

Q1 - We noticed there is no projection screen. Do we provide one?

A1 - We currently are not providing a projector screen for this project.

Q2 - Is there a control system in place or are we providing one?

A2 - There is no current control system - it is clearly marked FUTURE on AV0.031 and AV0.032. The Owner will have to use the remote to turn the Map projector on/off and remotes for the timeline & hall of fame displays, unless they just cut power to them at night.

Q3 - Should there be wall plates, floor boxes and/or table top touch screens for selecting sources?

A3 - See notes on AV location drawings for what is to be provided at the outset. Most equipment is "FUTURE".

Q4 - Are we putting together a full functioning AV system or do we only focus on what's on the equipment list?

A4 - The equipment list details the items that will be provided and installed initially. This includes the Map Wall projector, Timeline wall displays and signage players, and the Hall of Fame displays (one touch, one not) also with signage players. The Hall of Fame wall equipment is to be bid as "Add-Alt 10" as noted in the specification equipment list.

Q5 - There's a line item that says cabling but what type of cabling?

A5 - Cabling requirements are in the Schedule of Terminations on Sheet AV0.002 (Item "DIS")

PLEASE LOGIN USING THE INFORMATION ABOVE TO ACCEPT/REJECT THE INVITE AND TO DOWNLOAD PLANS