



DATE: January 23, 2018
SUBJECT: Letter of Clarification #2
RE: Equipment Purchase and Delivery ITB
TO: All Prospective Bidders

Houston First Corporation (“HFC”) issues this Letter of Clarification regarding the referenced Equipment and Delivery ITB to revise Section 261316 of the Specifications, titled “Medium Voltage Fused Switch Interrupter” in the following manner:

SECTION 26 13 16
MEDIUM VOLTAGE FUSED SWITCH INTERRUPTER

2.3 CONSTRUCTION

- C. The integrated fused switchgear assembly shall be rated for 600 amps and withstand the effects of closing, carrying and interrupting currents up to 65,000 amps short circuit rating.

2.6 PROTECTIVE DEVICES

- A. Provide current-limiting ~~400-Ampere~~ fuses of type recommended by the Manufacturer. Fuse ampacity shall be as indicated on drawings. Fuses shall have a 65,000 amperes symmetrical interrupting capability at 5 kV. Provide three fuses per switch and three spare fuses. Replace fuses used in testing with new fuses upon completion of testing.

In light of the foregoing revision to the Specifications, a corresponding change has been made to the Drawings (WT-1-E.4.00.1 and WT-1-E.4.00.2)

The Medium Voltage Fused Switch Interrupter specification, as revised, and the revised drawings are available online at www.houstonfirst.com/do-business.

Letters of Clarification become a part of the ITB automatically upon issuance, and supersede any previous specifications and/or provisions in conflict therewith. By submitting a bid, Bidders shall be deemed to have received all Letters of Clarification and to have incorporated them into their bid.